

## AIR RESOURCES BOARD

2020 L STREET  
P.O. BOX 2815  
SACRAMENTO, CA 95812



June 15, 1993

Ed St. Amour  
Northwest Region Manager  
Tokheim Corporation  
3323 Watt Avenue #290  
Sacramento, CA 95821

#93-12

Dear Mr. St. Amour:

Certification of Tokheim H422B, H426B, and H428B Dispensers

I received your letter of June 1, in which you requested certification of the Tokheim H422B, H426B, and H428B multi-product dispensers. According to your letter, the Tokheim H422B, H426B, and H428B dispensers are identical to the California Air Resources Board (CARB) certified Tokheim H422A, H426A, and H428A, except for the cabinet design which is only cosmetic and will not affect the vapor recovery system. Enclosed is a typical drawing of both the "A" series and the "B" series dispensers. This drawing depicts the cosmetic changes to the cabinet.

The Air Resources Board requires the approval of the Division of Occupational Health and Safety, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. Confirmation was received that the Tokheim H422B, H426B, and H428B dispensers were acceptable and that there was no objection to the certification of this equipment.

I find that the Tokhiem H422B, H426B, and H428B dispensers will not adversely affect vapor recovery systems on which they may be installed. Therefore, the Tokheim H422B, H426B, and H428B dispensers are certified for use with Phase II gasoline vapor recovery systems.

If you have any questions, please contact Christine McKenzie at (916) 324-7658 or Laura McKinney at (916) 327-1525.

Sincerely,



James J. Morgester, Chief  
Compliance Division

Enclosure

cc: Vapor Recovery Technical Committee